



GOOSENECKS REQUIRED FOR COPPER SERVICE PIPE ONLY. NO GOOSENECKS ALLOWED FOR HDPE SERVICE PIPE. PROVIDE SLACK IN TRENCH.

| SPRINGVILLE CITY CORPORATION WATER SERVICE INFORMATION | | | | | |
|--|----------------|--------------------------|--------------------------|-----------------|--------|
| SERVICE SIZE | METER BOX SIZE | YOKE/SETTER DESCRIPTION | WIDTH REQUIRED FOR METER | CONNECTION TYPE | BYPASS |
| 1" | 21" DIA. | FORD VBHC74-18W-11-44-NL | 11 1/16" | COMPRESSION | NO |
| 1 1/2" | 36" DIA. | FORD VBHH76-18W-11-66-NL | 13 1/2" | COMPRESSION | NO |
| 2" | 36" DIA. | FORD VBHH77-18W-11-77-NL | 17 1/2" | COMPRESSION | NO |

- NOTE:
- METER BOX AND SETTER INSTALLED BY DEVELOPER/CONTRACTOR.
 - WATER SERVICE TO BE STUBBED AT CENTER OF LOT.
 - ALL CONNECTIONS SHALL BE MADE USING PACK JOINTS (COMPRESSION) TYPE FITTINGS.
 - USE WATERPROOF GREASE NUT TO SPLICE LOCATOR WIRE.