



- NOTES:
1. ALL WORK MUST BE INSPECTED BY CITY WATER DEPARTMENT PRIOR TO BACKFILL.
 2. CONCRETE BLOCKING AND ADJUSTABLE STEEL PIPE SUPPORTS REQ'D. AS SHOWN.
 3. DIMENSIONS OF METER ASSEMBLY MAY VARY SLIGHTLY.
 4. ALL GALVANIZED FITTINGS AND NIPPLES MUST BE WRAPPED WITH PLASTIC.

LEGEND	
NO.	DESCRIPTION
1	4" x 2" TAPPING SADDLE DOUBLE STRAPPED
2	4" x 18" WELDED WALL SLEEVE M.J. x FLG.
3	4" GATE VALVE FLG. WITH WHEEL
4	4" COMPOUND METER
5	4" x 12" SPOOL FLG. x P.E.
6	4" SOLID SLEEVE M.J.
7	2" BALL VALVE
8	2" ELBOW
9	2" DRESSER COUPLING
10	2" METER
11	4" STRAINER